



ANTONIO R. VILLARAIGOSA
Mayor

Commission
THOMAS S. SAYLES, *President*
ERIC HOLOMAN, *Vice President*
RICHARD F. MOSS
CHRISTINA E. NOONAN
JONATHAN PARFREY
BARBARA E. MOSCHOS, *Secretary*

RONALD O. NICHOLS
General Manager

December 12, 2011

Mr. Mark Baldassari
Director, Codes and Standards
Enphase Energy
201 1st Street, Suite 300
Petaluma, CA 94952

Dear Mr. Baldassari:

Based on the following:

1. A Certificate of Compliance with UL-1741 from Canadian Standards Association (CSA).
2. A letter from Mr. Brij P. Aggarwal of CSA stating that Enphase Energy's interactive inverters have been evaluated against UL 1741, Subclause 40.1, using the utility interactive requirements in IEEE 1547.1.
3. A statement from CSA International, providing a table of all the tests listed in UL-1741 and IEEE 1547.1 that were conducted on Enphase Energy's Inverter Model M215.

The Los Angeles Department of Water and Power approves Enphase Energy's Model M215 utility interactive inverter as a qualified inverter for use with photovoltaic installations without requiring a system isolation transformer.

If you have any questions, please contact me at (213) 367-2707.

Sincerely,

Vahan Barseghian
Associate Engineer of Development and Standards

VB:sas

Water and Power Conservation ... a way of life

111 North Hope Street, Los Angeles, California 90012-2607 Mailing address: Box 51111, Los Angeles 90051-5700
Telephone: (213) 367-4211 Cable address: DEWAPOLA

